

ADDENDUM #2

1.1 PROJECT INFORMATION

- A. Project Name: **Asbestos and Universal Waste Removal, Former Morse High School 1941 and 1968 Additions, Bath, Maine.**
- B. Owner: **City of Bath, 55 Front Street, Bath, Maine.**
- C. Engineer: **Ransom Consulting, LLC, 400 Commercial Street, Suite 404, Portland, Maine.**
- D. Date of Addendum: **June 27, 2023.**

1.2 NOTICE TO BIDDERS

- A. This Addendum serves to clarify, revise, and supersede information in the Request for Proposals and Addendum #1. This Addendum also answers questions which were asked during the Pre-Bid walkthrough of the Site, which was held on *Thursday, June 22, 2023 at 9:00 a.m.* Portions of the Addendum affecting the Bid Form will be incorporated into the Bid Form by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.

1.3 SCHEDULE

- A. No changes to the schedule were made.

1.4 PRE-BID MEETING CLARIFICATIONS AND NOTES – PROJECT SPECIFIC

- A. Additional Sample Results: Samples of two additional suspect materials (laboratory countertops and white board glue daubs) were collected at the time of the pre-bid site walk on June 22, 2023. Laboratory results indicate the laboratory countertops are asbestos containing material and will need to be abated and disposed of as such. Ransom measured approximately 720 square feet of this material, located in Rooms 142, 146, 147, 148, and 149 on the second level of the 1968 addition. Laboratory results for the white board glue daubs indicate no asbestos was detected in the white board glue daubs. No abatement will be necessary for the glue daubs.

END OF ADDENDUM NO. 2